EMERGENCY LIGHTING
MONTHLY CHECK SHEET

Testing should be at intervals of between 3 and 5 weeks

Date	Result (Tick if OK)	Faults (specify)	Action taken	Signed

Monthly emergency lighting tests:

All emergency lighting systems must be tested monthly. The test is a short functional test in accordance with BS EN 50172:2004 / BS 5266-8:2004.
The period of simulated failure should be sufficient for the purpose of this test while minimising damage to the system components, e.g. lamps. During this period, all lighting units shall be checked to ensure that they are present, clean and functioning correctly.